



Energy Savings with Pump Systems


- How important are pump systems?
- Some pump system theory
- Prescreen pump systems: the VITAL FEW and the trivial many
- Identifying energy savings opportunities



Big Picture Perspectives: Industrial Motor Systems

➤ Industrial motor systems:


- Are the *single largest electrical end use* category in the American economy
- Account for 25% of U.S. electrical sales



Industrial motor energy use by application



Total 2.3 Quadrillion Btu/yr



Source: United States Industrial Electric Motor Systems Market Opportunities Assessment, Office of Industrial Technologies, Office of Energy Efficiency and Renewable energy, US DOE, December 1998, Table 1-16, page 43

University City Science Center
ITEM Division

Important fundamental relationship



$$\text{Fluid power} = \frac{\text{Flow rate (gpm)} \times \text{Head (ft)} \times \text{specific gravity}}{3960} \text{ (hp)}$$

AND

$$\text{Fluid energy} = \text{Fluid power} \times \text{operating time}$$

Reduce the run time


Reduce the flow rate

Reduce the head




Reduce energy use, cost

Ideally, fluid movement energy requirements are proportional to mass and head



Ideal power depends
on how fast it is moved




**Power required = 0.1 horsepower, or
65 kcalories per hour**



The Bernoulli equation is slightly modified to account for friction:

$$\left(\frac{V_1^2}{2g} + \frac{P_1}{g} + Z_1 \right) = \left(\frac{V_2^2}{2g} + \frac{P_2}{g} + Z_2 \right) + H_f$$



Pipe friction loss estimates are usually based on an equation referred to as
Darcy-Weisbach



This equation is very useful to understand what parameters influence *frictional* losses in piping:

$$H_f = f \cdot \frac{L}{d} \cdot \frac{V^2}{2g}$$

H_f = pressure drop due to friction (ft)

f = Darcy friction factor

L = pipe length (ft)

d = pipe diameter (ft)

$\frac{V^2}{2g}$ = velocity head (ft)



Component friction losses are primarily dependent on experimental data


For pipe components, frictional losses have generally been estimated based on the velocity head.

$$H_f = K \cdot \frac{V^2}{2g}$$


K = Loss coefficient
 $\frac{V^2}{2g}$ = velocity head

K is a function of size, and for valves, the valve type, and valve % open.

System head curves for all frictional,
all static, and combined static and frictional systems



The system operating point is at the intersection of the pump and system head-capacity curves



Pump affinity laws can be used to predict pump curves for different speeds and impeller diameters



$$\left(\frac{Q_1}{Q_2}\right) = \left(\frac{N_1}{N_2}\right)^1$$

$$\left(\frac{H_1}{H_2}\right) = \left(\frac{N_1}{N_2}\right)^2$$

$$\left(\frac{P_1}{P_2}\right) = \left(\frac{N_1}{N_2}\right)^3$$


$$\left(\frac{Q_1}{Q_2}\right) = \left(\frac{D_1}{D_2}\right)^1$$

$$\left(\frac{H_1}{H_2}\right) = \left(\frac{D_1}{D_2}\right)^2$$

$$\left(\frac{P_1}{P_2}\right) = \left(\frac{D_1}{D_2}\right)^3$$


Q = flow rate H = head P = power N = speed D = diameter

Isoefficiency lines are frequently overlaid onto head-capacity curves for multiple impeller diameters







Isoefficiency lines for different shaft speeds



Identical pumps in series; add head at a given flow rate to estimate overall performance




Parallel pumps can help adapt to changing system requirements and provide redundancy





Select the VITAL FEW and ignore the TRIVIAL MANY




Symptoms that indicate potential opportunity



<u>Symptom</u>	<u>Likely Reason</u>	<u>Best Solutions</u>
Throttle valve-controlled systems	Oversized pump	Trim Impeller, Smaller Impeller, ASD
Bypass line (partially or completely) open	Oversized pump	Trim Impeller, Smaller Impeller, ASD
Multiple parallel pump system with the same number of pumps always operating	Pump use not monitored or controlled	Install controls
Constant pump operation in a batch environment	Wrong system design	On-off controls
Frequent batch operation in a continuous process	Wrong system design	Match pump capacity with system requirement
Presence of cavitation noise (at pump or elsewhere in the process)	Various	Depends on cause
High maintenance cost (seals, bearings). Talk to operations personnel	Pump operated far away from B.E.P.	Match pump capacity with system requirement



Throttle valve-controlled system



Corrections for oversized pumps include:




- Replace the impeller of the existing pump with a smaller impeller
- Trim the outside diameter of the existing impeller
- Use an adjustable speed drive (ASD) to drive the pump


Bypass (recirculation) line partially or completely open




Bypass valve (completely or partially open)



Multiple parallel pump system with same number of pumps always operating




Three pumps in parallel



Take a good look at the diagram and you will see that the third pump (C) is intersecting the system curve at just about the same point as the second pump (B).

All of this means that the capacity of three pumps running will not be much greater than that of two pumps running.

Constant pump operation in a batch environment



Frequent cycle batch operation in a continuous process

